

IOR Energy PTY LTD
 ABN 60 010 504 444
 PO Box 14 Bulimba
 Brisbane QLD 4171 Australia
 Telephone: (07) 3895 4444
 Facsimile: (07) 3395 7902
 Web: www.ior.com.au
 Email: mail@ior.com.au



PRODUCT SPECIFICATION

ENERSOL KEROSENE

TEST	UNIT	TYPICAL	LIMIT	METHOD
Distillation Range				
IBP	°C	145		ASTM D86
5%*	°C		155 min	
95%*	°C		260 max	
FBP	°C	265		
Density @ 15°C*	kg/l	0.76	0.74 min 0.79 max	ASTM D4052
Colour	Saybolt	>24		ASTM D156
Flashpoint*	°C	42	38 min	ASTM D93
Sulphur	mg/kg	<15		ASTM D4294
Aromatics	vol%	5		GC
Benzene Content	vol%	<0.1		GC
Electrical Conductivity*	pS/m		200 min	ASTM D2624
Aniline Point	°C	74		ASTM D611

Properties marked with (*) will be tested and verified with the Certificate of Analysis.

Dangerous Goods Details

UN Number	1268
Dangerous Good Class	3
Subsidiary Risk	Not applicable
Packing Group	III
Hazchem Code	3W